

Rationalized design

Effective Measures	Corresponding Good Practices		Reference
	Code	Page	
Applying simplified intake screen	JP03	P59-60	
Power unit simplification and minimization of footprint by eliminating cooling water and oil pressure system for turbine generator, and by adopting integrated transformer with switchgear	JP05	P79	
Simplification of powerhouse building	NO01	P108	
Feasibility study on technical and economic aspects of hydropower generation utilizing surplus pressure in the conduit of water purification facility	ZA01	P191, P194	



Back